

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0410:147 Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Hochiki America, 7051 Village Drive, Suite 100, Buena Park, CA 90621-2268
Contact: Bob Misiuk (714) 670-3251*

DESIGN: Model ATG-EA electronic fixed temperature heat detector (analog) with Models YBN-NSA-4 and HSB-NSA-6 bases. Unit consists of resistors, capacitors, diodes, transistors, LED, thermistors, mounted on a printed wiring board inside an enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 39.5 VDC
Temperature Range: 134°F - 149°F

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical/temperature rating and UL label.

APPROVAL: Listed as heat detector for use with separately listed compatible fire alarm control units.

*Corrected 11-06-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**